

DEVICE & UTILITY LIST

JOB NUMBER
CUSTOMER

Total Connected Compressed Air (CFM) 0
Total Connected Horse Power (motor loads ONLY) 0.5



P.O. Box 4290
1101 Horizon Drive
Lawrence, KS 66046-1290

UPDATED DATE	EQUIP. TAG	DESCRIPTION	ID	COMP AIR			POWER		WIRING CONNECTIONS				
				CFM	VOLTAGE	PHASE	HP	A	B	C	D	E	
	1-001	BLOWER			480	3	25	T1	T2	T3	G		
	1-001	BLOWER MOTOR STARTER COIL			120	1		OUTPUT	N		G		
	1-001	BLOWER MOTOR STARTER AUX.			120	1		INPUT	H		G		
	1-001	BLOWER VACUUM BREAKER SOLENOID		4	120	1		OUTPUT	N		G		
	1-001	BLOWER VACUUM SWITCH			120	1		INPUT	H	N	G		
	1-003	FILTER RECEIVER PULSE TIMER		5.5	120	1		OUTPUT	N		G		
	1-005	FILTER RECEIVER HIGH LEVEL INDICATOR			120	1		INPUT	H		G		
	1-007	FILTER RECEIVER VIBRATOR SOLENOID		4	120	1		OUTPUT	N		G		
	1-0101	INLET ISOLATION ORIFICE GATE OPEN SOLENOID		0.5	120	1		OUTPUT	N		G		
	1-0101	INLET ISOLATION ORIFICE GATE OPEN PROOF SWITCH			120	1		INPUT	H	N	G		
	1-0101	INLET ISOLATION ORIFICE GATE CLOSED PROOF SWITCH			120	1		INPUT	H	N	G		
	1-0161	INLET ISOLATION ORIFICE GATE OPEN SOLENOID		0.5	120	1		OUTPUT	N		G		
	1-0161	INLET ISOLATION ORIFICE GATE OPEN PROOF SWITCH			120	1		INPUT	H	N	G		
	1-0161	INLET ISOLATION ORIFICE GATE CLOSED PROOF SWITCH			120	1		INPUT	H	N	G		
	1-006	SCALE HOPPER LOAD CELL A				DC		EXC+	EXC-	SIG+	SIG-	G	
	1-006	SCALE HOPPER LOAD CELL B				DC		EXC+	EXC-	SIG+	SIG-	G	
	1-006	SCALE HOPPER LOAD CELL C				DC		EXC+	EXC-	SIG+	SIG-	G	
	1-006	SCALE HOPPER LOAD CELL D				DC		EXC+	EXC-	SIG+	SIG-	G	
	1-006	SCALE HOPPER SUMMING BOX TO INDICATOR				DC		EXC+	EXC-	SIG+	SIG-	G	
	1-006	SCALE HOPPER INDICATOR TO PLC						???	???				
	1-008	DISCHARGE ORIFICE GATE OPEN SOLENOID		0.5	120	1		OUTPUT	N		G		
	1-008	DISCHARGE ORIFICE GATE OPEN PROOF SWITCH			120	1		INPUT	H	N	G		
	1-008	DISCHARGE ORIFICE GATE CLOSED PROOF SWITCH			120	1		INPUT	H	N	G		
	1-013	SILO DISCHARGE AIRLOCK MOTOR			480	3	1.5	T1	T2	T3	G		
	1-0161	INLET ISOLATION ORIFICE GATE OPEN SOLENOID		0.5	120	1		OUTPUT	N		G		
	1-0161	INLET ISOLATION ORIFICE GATE OPEN PROOF SWITCH			120	1		INPUT	H	N	G		
	1-0161	INLET ISOLATION ORIFICE GATE CLOSED PROOF SWITCH			120	1		INPUT	H	N	G		
	1-020	SILO DISCHARGE AIRLOCK MOTOR			480	3	1.5	T1	T2	T3	G		
	1-023	BIN VENT FILTER PULSE SOLENOID		6.4	120	1		OUTPUT	N		G		
	1-024	BIN VENT FAN			480	3	1.5	T1	T2	T3	G		
	1-024	BIN VENT FAN MOTOR STARTER COIL			120			OUTPUT	N		G		
	1-024	BIN VENT FAN MOTOR STARTER AUX.			120			INPUT	H		G		
	1-023	BIN VENT FILTER PULSE SOLENOID		6.4	120	1		OUTPUT	N		G		
	1-024	BIN VENT FAN			480	3	1.5	T1	T2	T3	G		
	1-024	BIN VENT FAN MOTOR STARTER COIL			120			OUTPUT	N		G		
	1-024	BIN VENT FAN MOTOR STARTER AUX.			120			INPUT	H		G		
	1-025	SILO HIGH LEVEL INDICATOR			120	1		INPUT	H		G		
	1-0251	SILO LOW LEVEL INDICATOR			120	1		INPUT	H		G		